

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 2137

Dated: 29/5/26

It is certified that an inspection team headed by

.....AVINASH SINGH PARMARTH..... EXECUTIVE ENGINEER, P.H. DIVISION
(Name of Officers with designation) GAYA-

from.....GAYA..... PHED

Inspected the AMAR JYOTI SCHOOL, DOMUHAN, PS- BODHGAYA, PO-
BODHGAYA, DIST- GAYAJI- 824231 on (date of

Inspection) and on the basis of Water Test Report (Attached) bearing no

..... dated20/5/2026.....

Of

..... (PHED Lab) certified that the AMAR JYOTI SCHOOL, DOMUHAN,
BODHGAYA (Name of school) has safe drinking water facilities for the students
and members of staff of the institution. School also maintains the, hygienic
sanitation condition in the school building & campus as per norms prescribed by
the Central/ State/U.T. Govt.

This certificate is valid till.....ONE YEAR.....

Signature with seal:

Name

AVINASH SINGH PARMARTH
26/5/2026
Executive Engineer
P.H. Division

Designation

: EXECUTIVE ENGINEER

Name & Address of the Officer/ Department

P.H. DIVISION, GAYA.

To

AMAR JYOTI SCHOOL, DOMUHAN, BODHGAYA
PS- BODHGAYA, PO- BODHGAGA
DIST- GAYAJI- 824231

Ms. m. Shresiamma Joseph

MANAGER
AMAR JYOTI SCHOOL
Domuhan, P.O.-Bhalua,
P.S.-Bodhgaya-824231 (Gaya)

Ragini Jeyo

Principal
Amar Jyoti School
Domuhan, Bodhgaya

Govt. Of Bihar
DISTRICT LEVEL WATER QUALITY TESTING LABORATORY (DLWQTL)
Public Health Engineering Department
P.H. DIVISION, GAYA

Physico-Chemical and Bacteriological Examination Report of Drinking Water Samples of Gaya																			
Sample Collected By :	Ragani Topo	AMAR JYOTI SCHOOL DOMUHAN, BODHGAYA										Sample Received on : 14/05/26							
		Block Name	Panchayat Name	Village	Wardno	Turb.	Conductivity	TDS	Hardness	Calcium	Magnesium	Chloride	Alkalinity	Fluoride	PH	Nitrate	Iron	Sulphate	Bacteria (+,-)
1	Bodhgaya	Bodhgaya	Bodhgaya	Desirable Limit	0.57	630	409	208	75.35	6.8	101	212	1.23	7.49	-	50	Absent		
Reporting Date :	20.05.26				1.00 NTU	-	500 (mg/l)	200 (mg/l)	75 (mg/l)	30 (mg/l)	250 (mg/l)	200 (mg/l)	1.00 (mg/l)	6.5-8.5	45 (mg/l)	200 (mg/l)	Absent		
missible Limit in absence of alternate source IS:10500:2012																			

*NR-No Relaxation, BDL-Below Detection Limit

जिद मरुवा न समर दिनांक 14.05.26
 Ragunindrapada द्वारा किया गया है ।

Ragunindrapada
 20.05.26

Chemist
 P.H. Division, Gaya

Ss.m. Shresiammajore
 MANAGER
AMAR JYOTI SCHOOL
 Domuhan, P.O.-Bhalua,
 P.S.-Bodhgaya-824231 (Gaya)

Ragini Joppo
 Principal
Amar Jyoti School
 Domuhan, Bodhgaya